



Certificate / Certificat Zertifikat / 合格証

UNP 2007117 C002

exida hereby confirms that the:

Lined Ball Valve

**UNP Polyvalves (India) Pvt. Ltd.
Gujarat - India**

Has been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-2

and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

**PFH/PFD_{avg} and Architecture Constraints
must be verified for each application**

Safety Function:

The Ball Valve will move to the designed safe position per the actuator design within the specified safety time.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.

The manufacturer
may use the mark:



Revision 2.0 March 05, 2024
Surveillance Audit Due
October 01, 2026



Evaluating Assessor

Certifying Assessor

UNP 2007117 C002

Systematic Capability: SC 3 (SIL 3 Capable)**Random Capability: Type A, Route 2_H Device****PFH/PFD_{avg} and Architecture Constraints
must be verified for each application****Lined Ball Valve****Systematic Capability:**

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets *exida* criteria for Route 2_H.

Versions:

Valve Type	Bore Sizes	Pressure Class
Lined Ball Valve – Side Split	1/2" – 12"	PN10
Lined Ball Valve – Centre Split	1/2" – 12"	PN6

IEC 61508 Failure Rates in FIT*

Static Application – Clean Service	λ_{SD}	λ_{SU}	λ_{DD}	λ_{DU}
Full Stroke	0	0	0	399
Tight Shut-Off	0	0	0	1337
Open on Trip	0	153	0	246

* FIT = 1 failure / 10⁹ hours

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report UNP 20-07-117 R005 V2R1 (or later)

Safety Manual: UNP-SM-01 V1R1 (or later)

